



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Certificate of constancy of performance, 0843-CPR-0138

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Protecta EX Mortar

Penetration Seal Classified for use in flexible & solid walls and solid floors

A mortar used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. Protecta EX Mortar is supplied as a dry material, and is mixed with water to the required ratio prior to installation.

placed on the market under the name or trade mark of

Polyseam AS

Ravneveien 7, Linnestad Næringsområde, N-3174 Revetal, Norway

and produced in the manufacturing plant(s)

15 St Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, UK

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA 13/0672, issued on 17/011/2017

and

ETAG 026-2 (used as an EAD)

under system AVCP 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 12th June 2013 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

17th November 2017

Mr. Chris Miles, Head of Notified Body



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0138

Product/Device description: Protecta EX Mortar

Applicant designation: Polyseam AS, Ravneveien 7, Linnestad Næringsområde, N-3174 Revetal, Norway

Product Information

Protecta EX Mortar
Mortar

The referenced product complies with:

A – All the relevant requirements as per ETA 13/0672

ETA valid issue date:

ETA 13/0672, issued on 17/11/2017

17th November 2017

Mr. Chris Miles, Head of Notified Body