



# EC CERTIFICATE

## Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

## Certificate of constancy of performance, 0843-CPR-0395

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Protecta FR Service Transit

Penetration Seal Classified for use in flexible & solid walls and solid floors

A cable box device used to form penetration seals where cables and conduits penetrate walls and floor constructions, where they have been provided with apertures for the penetration of services. Protecta FR Service Transit is supplied with intumescent liner complete within a hinged Polypropylene shell, to be closed around the services and inserted into the aperture in the supporting element.

placed on the market under the name or trade mark of

**Polyseam Ltd**

**15 St Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, United Kingdom**

and produced in the manufacturing plant(s)

**15 St Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, UK**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

**ETA 17/0695, issued on 17/011/2017**

and

**ETAG 026-2 (used as an EAD)**

under system AVCP 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

***constancy of performance of the construction product.***

This certificate was first issued on 17th November 2017 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

17<sup>th</sup> November 2017

Mr. Chris Miles, Head of Notified Body

UL International (UK) Limited  
Wonersh House, The Guildway, Old Portsmouth Road,  
Guildford, Surrey, GU3 1LR, United Kingdom

27-CP-F0855 Issue: 1.1



# EC CERTIFICATE

## Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

### Annex: Detailed information sheet

Certificate Number: 0843-CPR-0395

**Product/Device description:** Protecta FR Service Transit

**Applicant designation:** Polyseam Ltd, 15 St Andrews Road, Huddersfield, West Yorkshire, HD1 6SB

### Product Information

Protecta FR Service Transit  
Cable box

The referenced product complies with:

A – All the relevant requirements as per ETA 17/0695

### ETA valid issue date:

ETA 17/0695, issued on 17/11/2017

17<sup>th</sup> November 2017

Mr. Chris Miles, Head of Notified Body